CETEC
Professional Scientific Solutions

VOC Content Test Certificate

Wednesday August 18th, 2010

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137)

Sample Description: GS5 Seam Grip Adhesive

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Office Design V2 IEQ-13** **Green Star Office Interiors V1.1 IEQ-11**	**GS5 Seam Grip Adhesive**
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	**<50 grams per Litre as VOC content per material**
Specification **Green Building Council of Australia** **Green Star Office Design V3 IEQ-13**	**GS5 Seam Grip Adhesive**
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	**<50 grams per Litre as VOC content per material**

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1008-11

OHS & Environmental Care
Sustainability
Advanced Laboratory/Analytical Services
Technology & Innovation